

Memo No: 27.31.0000.200.45.001.136 Date: 01.02.2018



B-R POWERGEN LTD.
House:39, Road:12, Sector:04
Uttara Model Town, Dhaka-1230.

AMENDMENT-04

Appendixes, Section 20.6, Environmental Standards, Tender Document Vol-2 of 2 (Part-A) for Engineering, Design, Manufacturing, Inspection, Supply, Installation, Erection, Testing & Commissioning of Sreepur 150 ($\pm 10\%$) MW HFO Based Power Plant Project on turnkey basis at Sreepur, Gazipur, Bangladesh. Tender reference No: 27.31.0000.200.45.001.17.1225, Date: 28.11.2017, the following line will be added :

If any emission or other standard parameter (s) related to environment for HFO based Engine is not found in the ECR-1997 (Environment Conservation Rule) of Department of Environment (DoE) of Bangladesh, in that case latest edition of IFC, World Bank Guideline for Environment will be prevailed.

Kh 1.2.18
(Md. Khurshed Alam)
Company Secretary